



# GTEN 2021 Virtual Symposium

October 18<sup>th</sup> & 19<sup>th</sup>, 2021

## Innovations in Gas Turbine Technology to Answer the Emissions Challenge Towards Net-Zero Targets


Cristiano Balestrino  
Siemens Energy

Presentations are considered part of the public domain and will appear on the GTEN website and shared with attendees. The author(s) confirm that they, and/or their company or institution, hold copyright on all the original material included in their presentation. They also confirm they have obtained permission, from the copyright holder of any third-party material included in their presentation, to publish it as part of their presentation.

# CO<sub>2</sub> Net-Zero targets are increasingly a policy priority


Nearly 2/3 of the World's industrial CO<sub>2</sub> emissions being addressed in net-zero legislation or policy.

CO<sub>2</sub> emissions covered by commitment



Based on global CO<sub>2</sub> emissions by countries  
Source: [World Bank](#) (last updated: 07/21), emission data from 2018


- |                                      |                                       |
|--------------------------------------|---------------------------------------|
| Net-zero achieved (2)                | Net-zero in policy document (16)      |
| Net-zero embedded in law (10)        | Net-zero target under discussion (95) |
| Net-zero proposed in legislation (4) | No commitment yet (90)                |



Commitments of countries for Net-zero CO<sub>2</sub> emissions.  
Source: [Netzerotracker](#) (last updated: 07/21)

# The World needs to dramatically accelerate CO<sub>2</sub> emissions cuts to achieve net-zero by 2050

Energy and industrial process CO<sub>2</sub> emissions in WEO 2020 scenarios



1 Source: IEA World Energy Outlook 2020

## Energy Key Trends



**Decarbonization**



**Demand growth**




**Decentralization**



**Digitalization**

# What role can Gas Turbines play ?

## Energy Systems Decarbonization “Radar”



<https://www.siemens-energy.com/global/en/priorities/decarbonization/decarbonization.html>

## GT Decarbonization Levers

### Efficiency increase

- Repowering of ageing plants + displace coal
- Upgrades of existing assets
- Optimized operation (e.g. spinning reserve)
- Utilization of exhaust heat



### Fuel Shift/Hybridization

- Switch to low carbon fuels
- Integration of renewables, storage



### Deep Decarbonization

- Sector coupling, Power-to-X
- Green fuels (H<sub>2</sub> and others)




**+ continued focus on Air Quality**

Efficiency  
Increase



# Re-powering with highly efficient Gas Turbine plants




Modern GT plants reduce  $CO_2$  emissions through:

- Ideally supporting the displacement of high-carbon fuels e.g. coal
- Providing highly efficient energy conversion

## Decarbonization impact

- Combined Cycle fuel efficiency up to > 64% (gross)
- Major  $CO_2$  cuts when repowering from coal – up to 60% and more
- Ready for  $H_2$  blending, continuing roadmap development for up to 100%  $H_2$  fuel capability
- Ability to integrate with renewable sources & energy storage



**Reference case: 900 MW CCGT Cascade Power Plant reducing up to 5% of Alberta's Carbon emission from energy production**




# Gas Turbine efficiency mods & upgrades

- Most operating Gas Turbines are ageing units and often not running at their optimal efficiency.
- Technology refresh and operational optimization substantially improve CO<sub>2</sub> footprint with low CAPEX and risk.
- Reliability upgrades reduce the occurrence of unplanned outage / restart emissions.

## Example 1: Efficiency upgrades SGT-A20 (Industrial Avon)


- ☐ HEPA Air Filters
- ☐ Hot section upgrade (Avon 200)
- ☐ VIGV Closed Loop
- ☐ Bleed Valve Rescheduling



Up to **14% CO<sub>2</sub> reduction**, greatest benefit for part-load running

## Example 2: RT62X upgrade for SGT-A35 (Industrial RB211)


- ☐ Power Turbine 3D aerofoils
- ☐ Upgraded materials
- ☐ Can be configured as power up-rate or extended TBO



Up to **2.5% CO<sub>2</sub> reduction**, plus life cycle OPEX benefits

# Waste Heat utilization

## Useful energy without incremental emissions



### Features



- CHP / CoGeneration or District Heating with GTs is well established
- Bottoming Cycles with various types of Transfer media:
  - Water Steam Cycle – all ranges
  - Supercritical CO<sub>2</sub> Cycle for medium temperature operations
  - Organic Rankine Cycle (ORC) for water-free and low temperature operations
- High temperature heat pumps:
  - Generating high quality process heat
- Fuel preheating and anti-icing with waste heat

### Sustainability impact




- Increased overall fuel efficiency
- Energy without additional CO<sub>2</sub> -, CO-, NO<sub>x</sub> - or SO<sub>x</sub> emissions
- Relevant in all GT applications e.g. reducing carbon footprint of offshore upstream production



# Supercritical CO<sub>2</sub> power cycle

Increase power output and efficiency of simple cycle gas turbine installation, emissions-free.



- |                                |                                    |
|--------------------------------|------------------------------------|
| 1. Existing compressor station | 4. CO <sub>2</sub> Mass Management |
| 2. Primary Heat Exchanger      | 5. Cooling System (air or water)   |
| 3. Heat Engine + Auxiliaries   | 6. Electrical Service Building     |

## Pilot project



- Agreement with TC Energy to commission first-of-kind system at existing pipeline compression station in Alberta
- Convert waste heat from Gas Turbine into emissions-free power
- Supported by Emissions Reduction Alberta's (ERA) Industrial Efficiency Challenge

## Sustainability impact



- Generate electricity for 10,000 homes without additional fuel burn
- 10% increase in overall compressor station fuel efficiency
- 25 – 40% smaller footprint than steam-based systems
- Equivalent GHG reduction of 44,000 tons per year
- Potential to generate ~ 300 MW of emissions-free power from compression stations in Western Canada alone

# Dry Low Emissions (DLE) combustion


## Technology Focus

- Continuing regulatory drive to reduced NO<sub>x</sub> limits
- Improved part-load fuel efficiency e.g. CO “turn-down”
- Capability with low-carbon fuels e.g. Hydrogen
- Improve maintenance life cycle
- Incremental enhancement of proven designs
  - Ease of retrofit to installed units, and new units
  - Use Additive Manufacturing where beneficial

## Considerations

- Regulation has historically focused on NO<sub>x</sub> and CO
- However today’s global challenge are CO<sub>2</sub> emissions
  - Need to consider potential trade-offs
  - Focus the R&D investment to address the key priority

## SGT-A35 DLE enhancements






# SGT-400 13MW Enhanced DLE

## Full Engine Development Test



- April 2021 – demonstration test of SGT-400 with enhanced DLE
- Remote witness option for users via virtual link
- Single digit NO<sub>x</sub> and CO demonstrated
- Emissions maintained over 30-100% load range
- Up to 7% reduction in fuel burn / CO<sub>2</sub> in part load operation






**Enhanced DLE – Proven Technology. Lower GHG Emissions. Greater Operational Flexibility.**

# Fuel Shift / Hybridization



# Hybrid systems


## Integrating renewables, storage and gas-powered generation



- ❑ Fast-starting, flexible GTs significantly reduce the size / CAPEX of required energy storage
- ❑ Integrated GT & Battery Energy Storage Systems (GT-BESS) provide an ideal backup to renewable sources
- ❑ Competitively positioned in flexible electricity markets
- ❑ Ready for increased penetration of low-carbon fuels




# Gas Turbines support a transition to low carbon fuels



Ability of gas turbines and plants to use a mixture of natural gas and hydrogen to minimize CO<sub>2</sub> emissions.

## CO<sub>2</sub> Emissions from combustion only in lb/MMBTU

Source: EIA



**Blending of H<sub>2</sub> into Natural Gas can substantially lower CO<sub>2</sub> emissions in the power & industrial sectors**



# Hydrogen as a Gas Turbine fuel

## H<sub>2</sub> combustion physics vs. Natural Gas

### Higher reactivity and flame velocity

- Propensity to Auto-Ignition & Flashback in air / fuel mix

### Higher flame temperature



- Increased creation of NO<sub>x</sub> for high amounts of H<sub>2</sub>

### Lower energy content per unit volume


- Higher volume flow in fuel systems

### Explosivity characteristics

- Modifications in auxiliary protection systems



**WLE – Wet Low Emissions**  
(diffusion flame)



**DLE – Dry Low Emissions**  
(air / fuel pre-mixing)

### WLE combustion – up to 100% H<sub>2</sub> with little change


- ❑ Diffusion flame easier to manage
- ❑ Water injection to manage NO<sub>x</sub>
- ❑ Some auxiliary changes needed

### DLE combustion – up to 75% H<sub>2</sub> & viable roadmap to 100%

- ❑ Burner adjustments and testing
- ❑ Manage Auto-Ignition, Flashback, Combustion noise and Emissions
- ❑ Incremental technology matching GT cycle (e.g. pressure ratio)

# Upgrade of existing GT units for higher H<sub>2</sub> content

## Potential system upgrades to operate higher H<sub>2</sub> content



## Consequences and solution

- Project specific evaluation and decision on required modifications
- Power output control to ensure compliant NO<sub>x</sub> emission levels
- Conventional/non-H<sub>2</sub> fuels may be required for start-up and shutdown
- Re-certification with respective authorities might be required




EU Turbines has published Sep 2021 a common definition for H<sub>2</sub> readiness of GT plants: <https://www.euturbines.eu/h2-ready/>

# Deep Decarbonization



# Sector Coupling



## Sector Coupling Characteristics

## Definition


- Link between power sector and energy-consuming sectors
- Use energy vectors produced from renewable power (Power-to-X)
- Pathway to de-carbonize industrial sectors

## Value Proposition

- GHG reduction for sectors that are harder to electrify
- Utilization of excess renewable power by storage through chemical media
- Higher overall energy efficiency
- More diverse and interdependent energy supply

# Industrial-scale Renewable Hydrogen Power

## EU-funded HYFLEXPOWER Project (France)



### Description

- Brownfield transformation of existing GT site
- $H_2$  generation via electrolysis, compression & storage
- SGT-400 upgrade for up to 100%  $H_2$  pilot (DLE)

### Benefits

- Carbon savings 65,000 t p.a. (SGT-400 baseload)
- Store excess intermittent renewable energy
- Grants from EU (€10.5 mn funding EU Horizon 2020)

<http://www.hyflexpower.eu/>




# Other e-Fuel avenues to decarbonization

## Challenges of H<sub>2</sub> as Energy Vector

- Low energy density per mass
- Energy efficiency for transport over long distance
- Suitability of existing distribution infrastructure
  - Compression
  - Transport by pipeline
  - End users (industrial, residential, etc.)

## Alternative e-Fuels

	Pros	Cons
<b>Ammonia (NH<sub>3</sub>)</b>	<ul style="list-style-type: none"> <li>• Energy density</li> <li>• Easy to liquify</li> <li>• Known processes</li> </ul>	<ul style="list-style-type: none"> <li>• Toxic</li> <li>• Reactivity as fuel</li> <li>• NO<sub>x</sub> emissions</li> </ul>
<b>Methanol (CH<sub>3</sub>OH)</b>	<ul style="list-style-type: none"> <li>• Liquid fuel</li> <li>• Also made as biofuel / from waste</li> </ul>	<ul style="list-style-type: none"> <li>• Carries Carbon</li> <li>• E-Synthesis requires H<sub>2</sub>, CO<sub>2</sub></li> </ul>






# Methanol as Gas Turbine Fuel

**Sustainable Methanol can be produced from waste, as biofuel or as e-Fuel.**

Ideal replacement for Diesel fuel in Gas Turbines:

- Reduced CO<sub>2</sub> emissions
- Reduced NO<sub>x</sub> emissions (lower flame temp.)
- No Sulphur – improved maintenance OPEX and no NO<sub>x</sub> emissions
- No visible exhaust plume

Experience using as fuels for Aero GTs, upgrades needed mostly limited to fuel handling systems.



Rig testing of industrial Olympus showing NO<sub>x</sub> reduction of at least 80%

**Engine Demonstration testing planned for:**

- ❑ SGT-A20 (Industrial Avon)
- ❑ SGT-A35 (Industrial RB211)

# Conclusions

- ❑ **Transformation of Energy** is a reality
- ❑ Achieving **Net Zero targets is a huge challenge**...not one “ready” solution

## **Gas Turbines can contribute in all key levers of Decarbonization**

- ❑ **Energy efficiency** – displace coal, modernize the infrastructure
- ❑ **Fuel shift / Hybridization** – shift to lower carbon fuels, integration with Renewables
- ❑ **Deep Decarbonization** – sector coupling, “Power-to-X” models

**Collaboration between Industry & Regulators is needed to harness the benefits**

## Thank You for your attention!

[cristiano.balestrino@siemens-energy.com](mailto:cristiano.balestrino@siemens-energy.com)



# Disclaimer

This document has been prepared in respect of Siemens Energy AG (together with its subsidiaries, “**Siemens Energy**”), under which the majority of the energy business of Siemens Aktiengesellschaft (together with its subsidiaries, “**Siemens**”) will be bundled. It is intended to admit the shares in Siemens Energy to trading on the regulated market of the Frankfurt Stock Exchange. This document does not constitute or form part of any offer or invitation to sell or issue, or any solicitation of any offer to purchase or subscribe for, any shares or other securities of Siemens or Siemens Energy in any jurisdiction.

This document contains statements relating to the future business and financial performance and future events or developments involving Siemens and Siemens Energy that may constitute forward-looking statements. These statements may be identified by words such as “expect,” “look forward to”, “anticipate”, “intend”, “plan”, “believe”, “seek”, “estimate”, “will”, “project” or words of similar meaning. Such statements are based on the current expectations and certain assumptions, of which many are beyond Siemens’ and Siemens Energy’s control. These are subject to a number of risks and uncertainties. Should one or more of these risks or uncertainties materialize, should decisions, assessments or requirements of regulatory authorities deviate from our expectations, or should underlying expectations not occur or assumptions prove incorrect, actual results, performance or achievements of Siemens or Siemens Energy may (negatively or positively) vary materially from those described explicitly or implicitly in the relevant forward-looking statement. Neither Siemens nor Siemens Energy intend, nor assume any obligation, to update or revise these forward-looking statements in light of developments which differ from those anticipated.

The information and opinions contained in this document are provided as at the date of this presentation and are subject to change without notice. They do not purport to contain all information that may be required to evaluate Siemens or Siemens Energy and have not been verified independently. Historical financial or operative information contained in this document has been taken or derived from Siemens’ financial statements, accounting records or management reporting. The combined financial statements for Siemens Energy are currently being prepared. These may deviate substantially from the information included in this document. The information in this document is of a preliminary and abbreviated nature and may be subject to updating, revision and amendment, and such information may change materially. In addition, the historical financial and operative information included in this document does not necessarily fully reflect changes that will occur when Siemens Energy operates as a separate group of companies. Accordingly, such information is not necessarily indicative for the future consolidated results of operations, financial position or cash flows of the prospective Siemens Energy business on a stand-alone basis.

This document includes – in the applicable financial reporting framework not clearly defined – supplemental financial measures that are or may be alternative performance measures (non-GAAP-measures). These supplemental financial measures should not be viewed in isolation or as alternatives to measures of Siemens’ or Siemens Energy’s net assets and financial positions or results of operations as presented in accordance with the applicable financial reporting framework in its consolidated financial statements and combined financial statements, respectively. Other companies that report or describe similarly titled alternative performance measures may calculate them differently. Due to rounding, numbers presented throughout this and other documents may not add up precisely to the totals provided and percentages may not precisely reflect the absolute figures.

This document contains forecasts, statistics, data and other information relating to markets, market sizes, market shares, market positions and other industry data on Siemens’ or Siemens Energy’s business and markets (together the “**market data**”) provided by third party sources as interpreted by us. This market data is, in part, derived from published research and additional market studies prepared primarily as a research tool and reflects estimates of market conditions based on research methodologies including primary research, secondary sources and econometric modelling, which may not be representative.