



GTEN 2021 Virtual Symposium

October 18th & 19th, 2021

Carbon Emissions Reduction for Turbomachinery Guidance During the Energy Transition

Tim Kaminske & Jamie Bowen
on behalf of



Presentations are considered part of the public domain and will appear on the GTEN website and shared with attendees. The author(s) confirm that they, and/or their company or institution, hold copyright on all the original material included in their presentation. They also confirm they have obtained permission, from the copyright holder of any third-party material included in their presentation, to publish it as part of their presentation.

Introduction – Presenters




- Tim is an Application Engineer within the Aftermarket Engineered Solutions division at Siemens Energy.
- Currently tasked with developing aftermarket solutions that focus on adjusting centrifugal compressor performance and operating characteristics.
- Previously worked as a Product Design Engineer on the design, manufacture, and testing of Dresser-Rand centrifugal compressors.
- B.S. in Mechanical Engineering



- Jamie joined Dresser-Rand in 1989, which was acquired by Siemens in 2015
- Has held roles as Engineering Manager for Process Simulation, Package Engineering and Drafting. Plant Manager/Supervisor for Compressor Assembly, Package Assembly and Shipping. Manager for Corporate Product Configurator. Development and Senior Package engineer.
- Experience in Upstream, Midstream and Downstream Oil and Gas applications
- B.S. in Electrical Engineering

Discussion Topics

- Need for Carbon Emission Reduction
- Solutions for Turbomachinery
 - Unit Revamps & Changing Operating Points
 - Internal Leakage: Traditional vs Halo™ Seals
 - Dry Gas Seals
 - Remote Diagnostic Solutions
 - Dynamic Simulations
 - Fugitive Emissions – Reduction & Capture
- Q&A



Methane Emissions - Regulations

Summary of Regulations (per Compressor)

Region / Country	Current	After 1 st Jan'23
	SCFM / m3/Hr	SCFM / m3/Hr
Canada Federal	5.0 / 8.4	5.0 / 8.4
Alberta / BC Province	6.0 / 10.2	2.0 / 3.4
USA Federal	6.0 / 10.2	TBD
Globally	6.0 / 10.2	TBD



Extract from DACG (Mexico)

- Article 44 from the DOF– Replacing of Wet Seals or Capture the leakage.
- Article 46 from the DOF– Regulated parties must capture the gas from compressor purges (blowdown)
 - Primary: 'self-consumption or conservation'
 - Secondary: Gas is sent to a flare stack
- Article 53 from the DOF- Implement control measures even during maintenance / repair <5% total gas volume per year
- **Overall impact:** Compressor stations will be required to retrofit to reduce methane emissions from compressor seals or route emissions to a Vapor Recovery System

Unit Revamps

Revamp / ReRate (Brownfield)


Changing of existing compressor internals to adjust operating characteristics, either aerodynamic and / or mechanical

PROS

- Low Scope
- Fast Turnaround Time
- Great time to bundle upgrades (DGS) or use in place of parts order

CONS



- Has limitations based on existing equipment




Unit Revamps

Revamp Examples


- Add / Remove Impellers
- Adjust Impeller Designs
- Speed Increase / Decrease
 - Driver or Gear Change
- Process Control Change
 - Fixed → Variable Speed
- OEM or oOEM




Unit Revamps – Change in Operation



Unit Revamps – Change in Operation




Unit Revamps – Change in Operation



Unit Revamps


When to Revamp

- Changes in operating conditions
 - Gas composition/molecular weight
 - Capacity
 - Temperatures
 - Pressures
- Units built before mid-1980's
- Units over 10,000 horsepower
- During the early stages of outage planning
- During routine evaluations of your plant process
- Change in nominal operating point
- Before you purchase rotor/bundle spare parts
- Before you proceed with repairs to rotors/bundles



Unit Revamps - Efficiency

- Efficiency versus optimum flow range
- Improvements in compressor stage design
- Improvements in stage-to-stage selection of components
- Improvements in manufacturing technique
- Effects of operating off the peak design point




Unit Revamps – Value Proposition



Below is an example for a set of two Cooper RFA24 Pipeline units with Gas Turbine drivers


Existing Design:					
Casing	RFA24x2		Total Power	Cost Savings Analysis	
Machine	LP	HP		Train HP Savings	2,000 hp
Power (hp)	10,000	10,000		Eff.	8,000 (BTU/hr)/HP
			20,000	Total Energy Saved	16,000 MM BTU/hr
				Hrs. of Operation	8,760 hrs/yr
				Total Energy Saved	140,160 MM BTU
Proposed Revamp:	Assume ~10% More Efficient				
Casing	RFA24x2 RVP		Total Power	Average Cost of Natural Gas USD	\$ 5.29 / MM BTU
Machine	LP	HP		ESTIMATED	\$741,446
Power (hp)	9,000	9,000		ANNUAL SAVINGS	
Power Savings (hp):	1,000	1,000	2,000		
Power Savings:	10.00%	10.00%	10.00%		



Stationary Seals / Internal Leakage

- Labyrinth Seal
 - Tooth Design
 - Aluminum Standard
 - Upgrades / Non-Standard
 - Polymer
 - Corrosion Resistance
 - Improved wear resistance
 - Abradable / Rotating
 - Work in during run
 - Brush
 - Large bearing drops (Magnetic)
- *All conventional seals wear, and the performance of the compressor **degrades** with time and operation*


Pick the Right Seal for the Right Application!



HALO™ Seal Technology: Overview



- Directly replaces conventional straight-land seals.
 - Offers exceptional hydraulic performance.
 - Maintain design clearance and as-tested hydraulic performance through the entire run time, including end-of-run lifespan.
-
- Large install clearance
 - Pressure activated
 - Forces acting on the pad sets running design clearance; static pressure above and dynamic pressure below
 - Low Leakage
 - Non-contacting
 - Dynamic
 - Inconel material
 - Infinite Fatigue Life



HALO™ Seal Location and Value


SIEMENS
energy

EXAMPLE PROJECT

SynGas Make-up
High Pressure
2BF9-7 Compressor
Datum Stages

Power Savings & Payback

2000 TPD
9,800 HP
2000 psi
discharge




Methane Emissions - Reduction Dry Gas Seals




- Reduce the amount of Primary Vent leakage to atmosphere.
- In-house Technology: Engineering, Production, Services.
- 25+ Years of Experience / 30M+ Operating Hours
- API 692 Complaint
- Standard offering on New Equipment Solution.
- Ability to retrofit existing Installed Base – Dry or Wet Seals

Secondary Seal Supply (requires Nitrogen Source).



Courtesy: TAMU




Siemens DGS on Test Stand

Dry Gas Seal Upgrades - Benefits



Case Description	Wet Seals	Dry Gas Seals
Seal oil support system costs	Pumps, reservoirs, filters, Traps, coolers, consoles	None
Seal oil consumption	1-100 gallons/day	No seal oil
Maintenance costs	A major expenditure over equipment life	Negligible
Energy Costs	Seal power loss: 10-30 HP Unit driven pumps: 20-100 HP	1-2 HP
Process gas leakage	25 SCFM & Higher	<2 SCFM
Oil contamination	Of Pipeline: High clean-up costs Of Process: Catalyst poisoning	None
Toxic and corrosive applications	Buffer gas consumption 40-70 SCFM	2-4 SCFM
Unscheduled shutdowns	High down time costs	Very reliable
Rotor stability	Unpredictable with wear	Stable, predictable and reliable
Aborted startups	Frequent	Rare


Dry Gas Seal Upgrades - Experience










- **L-Line**

Standard configuration*


- To 3190 PSIG
- 17,000 rpm
- 356 F
- To 11.5 in
- Minimized hang-up



Remote Diagnostics - Main Measurements

-  Pressure
-  Temperature
-  Flow
-  Speed
-  Vibration
-  Position (% - open/close)
-  Level

- Recorded On-Site
- Shared in real-time with OEM
- Fast Response Time
- Pro Active Support
- Reduced Troubleshooting Time



Sensors




DAQ

OPC UA
Interface

Cloud



Remote Diagnostics – Failure Modes

Compressor



Remote Diagnostics – Failure Modes

Compressor Control



Main families of failure modes

Failure modes

Consequence(s)

Customer benefits
Reliability & availability

Process Control

- Recycle/surge control valve open
- Control system problem
- Compressor in surge
- Off-design gas composition



- Erratic system operation
- Poor compressor performance

- Efficiency Improvement
- Major failure avoidance
- Availability / reliability

Remote Diagnostics – Failure Modes

Dry Gas Seal

SIEMENS
energy



Main families of failure modes

Failure modes

Consequence(s)

Customer benefits
Reliability & availability

Dry Gas Seal



- Primary gas seal damage
- Leaking seal, gasket, or O-ring
- Liquid contamination
- Start-up / shutdown sequences

- Seal failure

- Major failure avoidance
- Availability / reliability
- Maintenance planning

Remote Diagnostics – Failure Modes

Gas Seal System



Main families of failure modes

Failure modes

Consequence(s)

Customer benefits
Reliability & availability

Gas Seal System

- Fouled/dirty filter
- Valve control
- Increased seal clearances
- Off design process conditions

- Erratic control
- High/low gas supply pressure and flow
- Dry gas seal and/or barrier seal failure

- Major failure avoidance
- Availability / reliability
- Maintenance planning

Dynamic Simulation – Digital Twin Modelling

- Digital Twin = Digital model design to replicate reality
- Full Compressor or Individual Aux System (DGS)
- Pre & Post Event Capabilities
- “Damage” different areas in system to replicate transient events
- Repeat Failures? Replicate site conditions to diagnose

Ex. using DYFLO Model






Figure 1 - Simple compressor model.

Greenhouse Gases (GHG) / Fugitive Emissions Capture Various Solutions




Criteria	Supersonic Ejector	GT Inlet	Enclosed Burner	Re-compression
Gas Turbine Driver	X	X	X	X
Electric Motor Driver			X	X
Scalable			X	X
Normal Operation	X	X	X	X
Shutdown Pressurized			X	X
Shutdown Vented			X	X
Shutdown ESD				
Re-injection into Suction	X			X
Re-injection into Discharge				X
Re-injection into alternate gas supply	X			X
Vent to atmosphere		X	X	

Methane Emissions – Capture Supersonic Ejector



- Designed for new equipment as well as exiting equipment with a GT driver.
- Scalable to accommodate 1 to 15 SCFM primary vent seal leakage.
- Designed for compressor normal operation.
- Pre-configured to re-inject into a heater inlet, fuel system inlet or alternate gas supply.
- Few moving parts so low maintenance solution


Methane Emissions – Capture Gas Turbine Inlet Reinjection



Compressor	Gas Turbine
RFBB20, RFA24, RFBB24	SGT-100 / SGT-300 / SGT-400
RFBB30, RFBB36, RFA36, RFBB42	SGT-A35
RFBB30, RFB36, RFA36, RFBB42	SGT-600, SGT-700, SGT-750


- Designed for new equipment as well as exiting equipment with a GT driver.
- Scalable to accommodate 1 to 15 SCFM primary vent seal leakage.
- Designed for compressor normal operation.
- Pre-configured to re-inject into inlet of GT.
- Few moving parts so low maintenance solution

Methane Emissions – Capture Enclosed Burner



- Combustors are designed to combust a waste gas stream as efficiently as possible.
- Enclosed burners greater than 99% destruction efficiency.
- Completely enclosed combustion prevents the environment from being exposed to IR radiation, heat and light.

Methane Emissions – Capture Recompression



- Recompress the DGS leakage into Process Pipe.
- Captures blowdown emissions during station depressurization, scheduled maintenance activities and planned shutdowns
- Scalability - one recompression system can be used for multiple centrifugal compressors operating in the same service
- Allows operators to meet or exceed current regulations
- Easily installed on a greenfield project

Siemens Energy is a registered trademark licensed by Siemens AG.

Q&A

SIEMENS
energy



Thank You
&
Any Questions?

